



YOUNG SHIRE COUNCIL

**WATER SERVICES – BENEATH
ROAD (RURAL ROADS)
POLICY**

NO 72

DATE ADOPTED: 21/8/13

Conditions relating to the installation of water pipes across roads:

1. Applications to be in writing.
2. A road opening permit must be obtained after Council approves a Traffic Control Plan.
3. The Minimum depth of cover to be 600mm in the table drain.
4. The pipe to be encased in an outer conduit to allow ready repair or access and upgrading of the supply.
5. all installation works on sealed and main gravel road shall be underbored between boundaries
6. Signs indicating the water line are to be located adjacent to the back cut of the table drain and / or fencelines.

Date Adopted: 17.3.10
Date Reviewed: 21/8/13

Resolution No. 43/10
Resolution No. 320/13